

7931

R14KF760

## AUCKLAND REGIONAL COUNCIL

### RESOURCE CONSENT

Granted Pursuant to the Resource Management Act 1991

COASTAL PERMIT NO. 927894

**GRANTEE: MANUKAU CITY COUNCIL**

#### CONDITIONS OF PERMIT:

Date of Expiration of Permit: 31 October 2027  
Territorial Authority: Manukau City Council  
Purpose of Permit: To erect an outfall structure within the coastal marine area. To use and occupy part of the coastal marine area for an outfall structure. To discharge stormwater.  
Site Location : Adjacent to the existing boat ramp at the eastern end of Sunkist Bay, Beachlands.  
Map Reference: NZMS 260 R11 8811782

#### SPECIAL CONDITIONS OF PERMIT:

1. That the works shall be undertaken generally in accordance with the details and plans submitted with the application.
2. That the consent holder shall advise the Manager, Coastal Resources Section, Auckland Regional Council of the date of commencement and completion of work.
3. Prior to the commencement of work the consent holder shall confirm with the Manager, Coastal Resources Section, Auckland Regional Council, final details of the construction method and programme for carrying out the works.
4. That all debris and surplus construction materials shall be removed from the coastal marine area and all damage to that area shall be reinstated to the satisfaction of the Manager, Coastal Resources Section, Auckland Regional Council.
5. That the consent holder shall maintain the works in good, sound condition but shall not modify, alter or extend these without having obtained all necessary approvals.
6. The right of occupation granted to the consent holder shall be limited to that part of the coastal marine area shown on plan no. 2285/3 titled Beachlands Sunkist Bay B1 Outfall.
7. That the maximum rate of stormwater discharge in a design storm of estimated 1 in 5 Annual Exceedance Probability shall be 480 litres per second.

927894

- 8 That for stormwater flows in excess of the capacity of the primary system, a secondary flow path be provided and maintained to allow surplus stormwater from critical storms, up to the one in 100 Annual Exceedance Probability event, to discharge with the minimum of nuisance and damage.
- 9 That a complete set of "as built" plans be submitted to the Group Manager, Environmental Management Department, within one month of the completion of the construction of the stormwater system.

**STANDARD CONDITIONS OF PERMIT:**

1. That this resource consent is granted by the Auckland Regional Council, subject to its servants or agents being permitted access to the relevant parts of the property at all reasonable times for the purpose of carrying out inspections, surveys, investigations, tests, measurements or taking samples.
2. That the Auckland Regional Council may at any time on the giving of not less than 3 months notice in writing serve notice on the consent holder of its intention to review any of the conditions of this consent for any of the following purposes :
  - i. To deal with any adverse effect on the environment which may arise from the exercise of the consent and which it is appropriate to deal with at a later stage; or
  - ii. To require a discharge permit holder to adopt the best practicable option to remove or reduce any adverse effect on the environment; or
  - iii. To deal with any other adverse effect on the environment on which the exercise of the Consent may have an influence.
3. The resource consent holder shall pay to the Auckland Regional Council any administrative charge fixed in accordance with s.36(1) of the Resource Management Act 1991, or any additional charge required pursuant to s.36(6) of the Resource Management Act 1991, payable in respect of this resource consent.

SIGNED AT AUCKLAND FOR AND ON BEHALF OF THE AUCKLAND REGIONAL COUNCIL



.....  
K E Connolly  
Group Manager  
**ENVIRONMENTAL MANAGEMENT**