

FILE

9579

Appendix I

AUCKLAND REGIONAL COUNCIL

RESOURCE CONSENT

Granted Pursuant to the Resource Management Act 1991

CONSENT NO. 937297

CONSENT HOLDER: Manukau City Council

CONDITIONS OF CONSENT:

Date of Expiration of Consent: 31 December 2027
Purpose of Consent: To divert and discharge stormwater from a 3.7 hectare existing residential catchment into an unnamed stream leading to the Tamaki Strait
Works: Piped stormwater system and concrete outfall structure
Site Location: Bell Rd / Third View Ave, Beachlands
Legal Description of Land: Lot 2 DP 97343
Territorial Authority: Manukau City Council
Map Reference: NZMS 260 R11:887779
Quantity: The maximum rate of discharge in a design storm of 1 in 5 Annual Exceedance Probability shall be 610 litres per second.

STANDARD CONDITIONS OF CONSENT:

1. This resource consent is granted by the Auckland Regional Council, subject to its servants or agents being permitted access to the relevant parts of the property at all reasonable times for the purpose of carrying out inspections, surveys, investigations, tests, measurements or taking samples.
2. That the Auckland Regional Council may at any time on the giving of not less than 3 months notice in writing serve notice on the consent holder of its intention to review any of the conditions of this consent for any of the following purposes:
 - (i) To deal with any adverse effect on the environment which may arise from the exercise of the consent and which it is appropriate to deal with at a later stage; or
 - (ii) To require a discharge permit holder to adopt the best practicable option to remove or reduce any adverse effect on the environment; or
 - (iii) To deal with any other adverse effect on the environment on which the exercise of the consent may have an influence and the following special conditions:
3. The resource consent holder shall pay to the Auckland Regional Council any administrative charge fixed in accordance with s.36(1) of the Resource Management Act 1991, or any additional charge required pursuant to s.36(6) of the Resource Management Act 1991, payable in respect of this resource consent.


SPECIAL CONDITIONS OF CONSENT NO 937297:

1. That the outfall be terminated with a structure of such location, design and performance as to minimise erosion, risk of obstruction of the waterway and hazards to safety. The said outfall structure shall be maintained by the Grantee to the preceding standards.
2. That for stormwater flows in excess of the capacity of the primary system, a secondary flow path be provided and maintained to allow surplus stormwater from critical storms, up to the one in 100 Annual Exceedance Probability to discharge with the minimum of nuisance and damage.
3. That the Grantee prepare an Environmental Impact Assessment Report relating to this discharge and its receiving waters.
4. That the Grantee address the issue of stormwater quality from this development and demonstrate to the Group Manager, Environmental Management, that the proposed measures are the "best practicable option" for this situation.
5. If the "best practicable option", referred to in special condition No 4, includes structural control devices then the Grantee shall prepare a maintenance and disposal plan for the proposed system.
6. That the designs, plans, proposals and report referred to in special conditions Nos 1 through 5 be submitted to, and approved by the Group Manager, Environmental Management prior to construction of the stormwater system.
7. That a complete set of "as built" plans be submitted to the Group Manager, Environmental Management, within one month of completion of the construction of the stormwater system.

SIGNED AT AUCKLAND FOR AND ON BEHALF OF THE AUCKLAND REGIONAL COUNCIL

KE Connolly
Group Manager
ENVIRONMENTAL MANAGEMENT

Per



.....