



NOMINAL BORE	MINIMUM WALL THICKNESS	APPROXIMATE EFF. LENGTH
225	32	1.83m
300	32	2.44m
375	32	2.44m

Note:

Wall thickness may be increased depending on the thrust loads.

MANARC
MANUKAU CITY APPROVED
REQUIREMENT

DETAIL:

**STORMWATER PIPE
THRUSTING JOINT DETAILS**

UPDATED:

OCT 2003

DETAIL No:

MD-7

MANUKAU CITY COUNCIL