



Rubber Ring Jointing system
of an approved standard

The pipes shall comply with:

- (i) NZS/AS 1260 for 100mm.
- (ii) NZS/AS 1477 for 150mm.

It shall be coloured grey to NZS/AS 1260 and have the following identification as per NZS/AS 1260 in blue print.

(i) For 100mm Supertuff:

IPLEX PIPELINES SUPERTUFF SEHC DWV 1500.ST.HD.100PVC. AS/NZS 1260, year, month, day PN

(ii) For 150mm Supertuff:

IPLEX PIPELINES SUPERTUFF SEHC SI PVC 150 PN9, year, month, day PN AS/NZS 1477.

The following diameter and wall thickness shall comply with the following:

Nominal Diameter	Outside Diameter	Minimum Wall Thickness
100mm	110.2 ± 0.2mm	4.1mm
150mm	160.25 ± 0.25mm	6.3mm

Note:

1. Not to be used under carriageways.

MANARC

MANUKAU CITY APPROVED
REQUIREMENT

DETAIL:

SUPERTUFF PVC STORMWATER PIPE
SIZES 100mm ANS 150mm

UPDATED:

AUG 2006

DETAIL No:

MD-26

MANUKAU CITY COUNCIL