



GOUGHLITE 500

Refer to hard copy of MANARC for photograph

GOUGHLITE EC

Refer to hard copy of MANARC for photograph

STANDARD INSTALLATION APPROVAL

| Carriageway width (m) | H (m) | Pole Spacing (m) | Outreach (m) | HPS Bulb Wattage |
|-----------------------|-------|------------------|--------------|------------------|
| 5.4                   | 5.8   | 46               | 0.9          | 70               |
| 7.8                   | 5.8   | 46               | 0.9          | 70               |
| 7.8                   | 7.3   | 58               | 0.9          | 70               |

GOUGHLITE 600

Refer to hard copy of MANARC for photograph

INSTALLATION APPROVAL

For road carriage way 10.8m at mounting height of 8.6m and carriage ways of 12.2 width and above at mounting height of 11.75 (or above for special dispensation) HPS bulb wattages 150 or 250. Computer based design required to show compliance to NZS 6701. Aeroscreen variant available for use near airport.

GOUGHLITE 700

Refer to hard copy of MANARC for photograph

INSTALLATION APPROVAL

For main road installations only and mounting heights of 11.75m (or above by special dispensation). HPS bulb wattages 150 or 250 (or greater by special dispensation) Computer based design required to show compliance to NZS 6701.

**MANARC**  
MANUKAU CITY APPROVED  
REQUIREMENT

UPDATED:  
**SEPT 1998**

DETAIL No:  
**MR-34**

DETAIL:  
**GOUGH MANUFACTURING  
STREET LIGHTING LUMINAIRES  
GOUGHLITE 500, 600, 700 & EC**

**MANUKAU CITY COUNCIL**