



*900-**1200



* 500
** 675

- * Bega/Conlux 7166 for minor roads
- ** Bega/Conlux 7559 for intermediate roads

BEGA/CONLUX 7166

STANDARD INSTALLATION APPROVAL

Carriageway width	H m	Pole Spacing m	HPS Bulb Wattage
5.4	6.0	50	70
7.8	7.0	50	70

BEGA/CONLUX 7559

Computer based design is required for Intermediate roads to show compliance to NZS 6701

Note:

1. Curved pipe to be true in both directions and vertical sections parallel
2. All components hot dip galvanised and polyester powder-coated, "Federation Green or Hawthorn Green".

COLUMN

Oclyte or Steelgal column

±



MANARC

MANUKAU CITY APPROVED REQUIREMENT

DETAIL:

BEGA/CONLUX 7166 & 7559

UPDATED:

APR 2003

DETAIL No:

MR-36

MANUKAU CITY COUNCIL