



Notes:

1. Luminaire to be only used with Manarc approved poles or columns.
2. Luminaire to be only used for amenity type situations with specific MCC approval. Not to be used for street lighting.
3. Luminaire to comply with MCC Public Lighting Design Standard requirements and
 - (a) Be manufactured in accordance with AS/NZS 60598.1 and tested in accordance with AS/NZS 60598.2.
 - (b) Have steel materials and fasteners complying with NZS 3404.1 or AS 4100.
 - (c) Dissimilar metals shall not be in contact with each other.
 - (d) Have lighting complying with AS/NZS 1158.
 - (e) Have luminaire and control gears that are readily accessible and easily maintainable without using special tools.
 - (f) Use metal halide lamps.
 - (g) Use 250, 150 and 70 standard lamp wattages.

MANARC

MANUKAU CITY APPROVED
REQUIREMENT

DETAIL:

PHILIPS MINI 300 LUMINARIES

UPDATED:

JUL 2004

DETAIL No:

MR-42

MANUKAU CITY COUNCIL