



Notes:

1. Approved are Vicpole Bentley series column, single outreach arm, Ezi-Fit base & Greendale 570 luminaire.
2. Column to comply with MCC Public Lighting Design Standard and:
 - (a) In accordance with AS1400, AS1789, AS1170 part 2, AS 1365, AS1554 and AS2312.
 - (b) Be installed in accordance with NZ Building Code and AS/NZA1158.1.3.
 - (c) Shall be hot dipped galvanised to AS/NZS4680 with two pack paint finish.
3. Column to be installed in accordance with manufacturer's recommendation.

MANARC

MANUKAU CITY APPROVED
REQUIREMENT

UPDATED:

OCT 2005

DETAIL No:

MR-53

DETAIL:

GREENDALE 570 LAMP & VICPOLE
BENTLEY SERIES COLUMN

MANUKAU CITY COUNCIL